

December 4, 2025

306-741-5421

Via Email: villageofbroderick@gmail.com

Village of Broderick
Box 29
BRODERICK SK S0H 0L0

Attention Waterworks Owner/Operator:

RE: Precautionary Drinking Water Advisory for *the Village of Broderick*: - Rescinded

The Water Security Agency, in consultation with Saskatchewan Health Authority is advising that the “Precautionary Drinking Water Advisory” (PDWA) issued by the Water Security Agency for the *Village of Broderick*’s water distribution system has been rescinded, effective immediately.

The rescinding of the PDWA was based upon information provided by your operational staff, which included:

- The receipt of two consecutive sets of three (6 total) bacteriological samples collected 24 hours apart from the water distribution system are negative for bacteriological growth.

You may return to normal water quality monitoring requirements as detailed in your Permit to Operate a Waterworks. Thank you for your cooperation during this event. For further information please contact the undersigned at 306-741-5421 or Andrew.Hickey@wsask.ca.

Sincerely,



Andrew Hickey
Environment Officer
Water Security Agency

cc: Don Turner - Manager, Compliance Promotion South, WSA (email)
Water Advisories, Water Security Agency
Saskatchewan Health Authority, Rosetown Office