



September 29, 2025

306-551-9412

Via Email: villageofbroderick@yourlink.ca

Village of Broderick
Box 29
BRODERICK SK S0H 0L0

Attention Waterworks Owner/Operator:

RE: Precautionary Drinking Water Advisory for *the Village of Broderick*: - Rescinded

The Water Security Agency (WSA) is satisfied with *two sets of* negative bacteriological sampling and adequate disinfection residuals and turbidity values from samples that have been collected from the water distribution system following replacing filter media which caused **the** unknown water quality. Therefore, effective immediately the WSA is rescinding the “**Precautionary Drinking Water Advisory**” for the residents and users of the *Village of Broderick* water supply.

For further information, please do not hesitate to contact the undersigned at 306-741 5421 or andrew.hickey@wsask.ca.

Sincerely,

A handwritten signature in black ink, appearing to read "A. Hickey".

Andrew Hickey
Environment Officer
Water Security Agency

cc: Don Turner - Manager, Compliance Promotion South, WSA (email)
Water Advisories, Water Security Agency
Saskatchewan Health Authority, Rosetown Office